



By E-Mail
E-Mail ID cdupjn_amroha@yahoo.com

कार्यालय
अधिशाली अभियन्ता, खण्ड कार्यालय, उ०प्र० जल निगम (ग्रामीण),
अमरोहा - 244221

पत्रांक 380 / प्रयोगशाला अम० 03 दिनांक 31-01-2025
सेवा में,

The Aaryans
A Senior Secondary Co-educational School
Prem Nagar Joya
Amroha


विषय- पानी की जांच के संबंध में।

महोदय,

उपरोक्त विषयक The Aaryans Senior Secondary School Prem Nagar Joya Distt. Amroha दिनांक 23.01.2025 को सचिन कुमार शर्मा (ऑफिस) द्वारा उपलब्ध कराये गये पेयजल नमूने की जांच खण्डीय प्रयोगशाला में की गयी। जांचोपरान्त जांच रिपोर्ट संलग्न कर प्रेषित है।

संलग्नक:- उपरोक्तानुसार।


भवदीय



(चन्द्रहास)

अधिशाली अभियन्ता

पृ०सं० एवं दिनांक उपरोक्तानुसार।

प्रतिलिपि:- सहायक अभियन्ता/जू०इंजी० लैब को सूचनार्थ हेतु प्रेषित।


अधिशाली अभियन्ता


31/01/25



TC-13405

ANALYSIS REPORT

District Level Water Analysis Laboratory U.P, Jal Nigam (Rural) Amroha
Address- Atrasi to Joya bypass Road near R.T.O Office Amroha Uttar Pradesh Pin-244221

Report No.	300	Date	31/01/2025	Page No.	
Customer Details					
Office Name and Address		The Aaryans A Senior Secondary Co-educational School Affiliated to CBSE, Prem Nagar Joya			
Ref Letter No & date					
Basic details of sample					
District	Amroha	Block	Joya		
Gram Panchayat	Prem Nagar Joya	Village	-		
Habitation	-	Location	The Aaryans A Senior Co-educational School		
Water Source	R.O. Plant	Sample No.	AMR/C/25/1720		
Quantity of Sample	1 Lt	Date of S.C	23/01/2025		
Receiving Date	23/01/2025	Sample Collector	Self		
Sample Submit	23/01/2025	Sampling Method Used	IS 17614 (Part 1):2024		
Analysis	Chemist/Lab Assistant				
Analysis Start Date	25/01/2025	Analysis Completion date-	27/01/2025	Result Availability Date-	28/01/2025

Environmental Condition

Temperature	25±3°C	Relative Humidity	Upto 50±15
-------------	--------	-------------------	------------

Technical Data of Analysis

S.R	Analysed Parameters (Unit of Measurement)	Observed Value	Specified Values as per IS 10500:2012		Ref Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	Colour (HU)	16	5	15	IS 3025 P-4:2021
2	pH	7.88	6.5-8.5	6.5-8.5	IS 3025 P-11:2022
3	TURBIDITY (NTU)	1.829	1.0	5.0	IS 3025 P-10:2023
4	TDS (mg/l)	88.77	500	2000	IS 3025 P-16:2023
5	CHLORIDE (mg/l)	40.00	250	1000	IS 3025 P-32:2019
6	TOTAL ALKALINITY (mg/l)	220.00	200	600	IS 3025 P-23:2023
7	TOTAL HARDNESS(mg/l)	300.00	200	600	IS 3025 P-21:2019
8	Fluoride (mg/l)	.014	1.0	1.5	Apha23th edition-4500 F Method C (Electrode method):2023

Note -

1. This Certificate refers only to the particular sample(s) submitted for testing..
2. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of send under the stated conditions of measurements.
4. Sample will be stored up to 7 days. (in case of non-perishable items only) from the date of issue of tests report unless.

Quality Manager
District Level Water Analysis Laboratory
Authorized Signatory



ANALYSIS REPORT

District Level Water Analysis Laboratory U.P, Jal Nigam (Rural) Amroha
Address- Atrasi to Joya bypass Road near R.T.O Office Amroha Uttar Pradesh Pin-244221

Report No. 380 Date 31/01/2025 Page No. 1

Customer Details

Office Name and Address The Aaryans A Senior Secondary Co-educational School
Affiliated to CBSE, Prem Nagar Joya
Ref Letter No & date

Basic details of sample

District	Amroha	Block	joya
Gram Panchayat	Prem Nagar Joya	Village	-
Habitation	-	Location	The Aaryans A Senior Co-educational School
Water Source	RO Plant	Sample No.	AMR/C/25/1720
Quantity of Sample	1 Lt	Date of S.C	23/01/2025
Receiving Date	23/01/2025	Sample Collector	Self
Sample Submit	23/01/2025	Sampling Method Used	IS 17614 (Part 1):2024
Analysis	Microbiologist1		
Analysis Start Date	25/01/2025	Analysis Completion date-	27/01/2025
		Result Availability Date-	27/01/2025

Environmental Condition


Temperature	25±3°C	Relative Humidity	Upto 50±15
-------------	--------	-------------------	------------

Technical Data of Analysis

S.R	Analysed Parameters (Unit of Measurement)	Observed Value	Specified Values as per IS 10500:2012		Ref Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	E.coli	0.0	Shall not be detectable in 100 ml sample		IS 15185:2016
2	Total Coliform	0.0	Shall not be detectable in 100 ml sample		IS 15185:2016

Note –

1. This Certificate refers only to the particular sample(s) submitted for testing..
2. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of send under the stated conditions of measurements.
4. Sample will be stored up to 7 days. (in case of non-perishable items only) from the date of issue of tests report unless.


Authorized Signatory
(Microbiologist)

.....End Of The Report.....